

VILLAGE OF BARRINGTON HILLS

112 Algonquin Road, Barrington Hills, IL 60010-5199

P: 847.551.3000 | F: 847.551.3050

www.barringtonhills-il.gov

TO: Board of Trustees**FROM:** Trustee Gohl**RE:** Building & Grounds Activity**DATE:** 05/27/2015

Village Hall: New Catalpa tree planted at the main entrance to replace the large Sugar Maple removed last fall.

During semiannual preventive maintenance of all HVAC units, it was determined that #4 has a bad control board and does not work in heat mode.

Fire Guard conducted semi-annual fire sprinkler system test and passed.

Cintas completed the quarterly bathroom sanitizing.

Fire Station: Kipp Plumbing has rodded the apparatus bay trench drain system and has completed the televising of the septic, storm and water softening lines to identify any issues and discharge locations. No issues were detected and it was determined that the trench drain and water softener systems discharge into the storm drains and not the septic system.

Safety-Kleen pumped out the apparatus bay oil and water separator floor basins.